



10	Controlled Outlet Valve	Optionally Supplied
9	Drain Header	Customer Supplied
8	1-1/2" or 2" Drain Line	Customer Supplied
7	1-1/2" or 2" Rinse Valve	Supplied with Filter
6	OMNITROL 4000E Controller	PLC in NEMA 4X Enclosure
5	3- Way Solenoid Valve	24 Vac, 60 Hz, N.O.
4	Differential Pressure Switch	Preset to 7 psi
3	Outlet Isolation Valve	Customer Supplied
2	System Bypass Valve	Customer Supplied
1	Inlet Isolation Valve	Customer Supplied
No.	Description	Notes

DWG. NO. 3003A	SCALE: NONE	INSTALLATION LAYOUT FOR A TYPICAL ORE/A SERIES FILTER WITH BYPASS & COV
		<b>ORIVAL, INC.</b> 213 S. VAN BRUNT ST. ENGLEWOOD, N.J. 07631 TEL (201) 568-3311, FAX (201) 568-1916 www.orival.com -- filters@orival.com
DRAWN BY: G KALINOWSKI	DATE: 12/10/15	