



9	Controlled Outlet Valve	Optionally Supplied
8	Drain Header	Customer Supplied
7	1-1/2" or 2" Drain Line	Customer Supplied
6	1-1/2" or 2" Rinse Valve	Supplied with Filter
5	OMNITROL 4000E Controller	PLC in NEMA 4X Enclosure
4	3- Way Solenoid Valve	24 Vac, 60 Hz, N.O.
3	Differential Pressure Switch	Preset to 7 psi
2	Outlet Isolation Valve	Customer Supplied
1	Inlet Isolation Valve	Customer Supplied
No.	Description	Notes

DWG. NO. 3004A	SCALE: NONE	INSTALLATION LAYOUT FOR A TYPICAL ORE/A SERIES FILTER WITH COV W/O BYPASS
		ORIVAL, INC. 213 S. VAN BRUNT ST. ENGLEWOOD, N.J. 07631 TEL (201) 568-3311, FAX (201) 568-1916 www.orival.com -- filters@orival.com
DRAWN BY: G KALINOWSKI	DATE: 12/10/15	