



| 9 | Motor Controller | Part of the OMNITROL 3000 |
|-----|------------------------------|---------------------------|
| 8 | Drain Header | Customer Supplied |
| 7 | Drain Line | Customer Supplied |
| 6 | Rinse Valve | Supplied with Filter |
| 5 | OMNITROL 3000 Controller | PLC in NEMA 4X Enclosure |
| 4 | 3- Way Solenoid Valve | 24 Vac, 60 Hz, N.O. |
| 3 | Differential Pressure Switch | Preset to 7 psi |
| 2 | Outlet Isolation Valve | Customer Supplied |
| 1 | Inlet Isolation Valve | Customer Supplied |
| No. | Description | Notes |

| | | |
|---------------------------|-------------------|--|
| DWG. NO. 3002B | SCALE: NONE | INSTALLATION LAYOUT FOR A TYPICAL ORE/B SERIES FILTER WITHOUT BYPASS OR COV |
| | | ORIVAL, INC. 213 S. VAN BRUNT ST. ENGLEWOOD, N.J. 07631 TEL (201) 568-3311, FAX (201) 568-1916 www.orival.com -- filters@orival.com |
| DRAWN BY: G KALINOWSKI | DATE: 09/28/17 | |